

Department of Energy

§ 830.120

safety structures, systems, and components and their support systems required for safe operations are maintained, that facility operation is within safety limits, and that limiting control settings and limiting conditions for operation are met.

Technical safety requirements (TSRs) means the limits, controls, and related actions that establish the specific parameters and requisite actions for the safe operation of a nuclear facility and include, as appropriate for the work and the hazards identified in the documented safety analysis for the facility: Safety limits, operating limits, surveillance requirements, administrative and management controls, use and application provisions, and design features, as well as a bases appendix.

Unreviewed Safety Question (USQ) means a situation where

(1) The probability of the occurrence or the consequences of an accident or the malfunction of equipment important to safety previously evaluated in the documented safety analysis could be increased;

(2) The possibility of an accident or malfunction of a different type than any evaluated previously in the documented safety analysis could be created;

(3) A margin of safety could be reduced; or

(4) The documented safety analysis may not be bounding or may be otherwise inadequate.

Unreviewed Safety Question process means the mechanism for keeping a safety basis current by reviewing potential unreviewed safety questions, reporting unreviewed safety questions to DOE, and obtaining approval from DOE prior to taking any action that involves an unreviewed safety question.

Use and application provisions means the basic instructions for applying technical safety requirements.

(b) Terms defined in the Act or in 10 CFR Part 820 and not defined in this section of the rule are to be used consistent with the meanings given in the Act or in 10 CFR Part 820.

§ 830.4 General requirements.

(a) No person may take or cause to be taken any action inconsistent with the requirements of this part.

(b) A contractor responsible for a nuclear facility must ensure implementation of, and compliance with, the requirements of this part.

(c) The requirements of this part must be implemented in a manner that provides reasonable assurance of adequate protection of workers, the public, and the environment from adverse consequences, taking into account the work to be performed and the associated hazards.

(d) If there is no contractor for a DOE nuclear facility, DOE must ensure implementation of, and compliance with, the requirements of this part.

§ 830.5 Enforcement.

The requirements in this part are DOE Nuclear Safety Requirements and are subject to enforcement by all appropriate means, including the imposition of civil and criminal penalties in accordance with the provisions of 10 CFR Part 820.

§ 830.6 Recordkeeping.

A contractor must maintain complete and accurate records as necessary to substantiate compliance with the requirements of this part.

§ 830.7 Graded approach.

Where appropriate, a contractor must use a graded approach to implement the requirements of this part, document the basis of the graded approach used, and submit that documentation to DOE. The graded approach may not be used in implementing the unreviewed safety question (USQ) process or in implementing technical safety requirements.

Subpart A—Quality Assurance Requirements

§ 830.120 Scope.

This subpart establishes quality assurance requirements for contractors conducting activities, including providing items or services, that affect, or may affect, nuclear safety of DOE nuclear facilities.